

一般廃棄物処理施設の維持管理記録(CO濃度)

日 \ 月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1		5	4	3	3	4		5	3			
2		3	6		4	4	8	16				
3	4	3		8	6		2					
4	3	4		3	4	4	3		13			
5	3	2	4	3	4	8	3		4			
6	3	4	5	4		7	5	4	4			
7	6		4	3	10	5	2	5	3			
8	3	4	2	4	7	11		4	3			
9		3	3		6		4	2				
10		2		8	4		3	3				
11	3	3		3	7	7	4		13			
12	3	3	4	2	2	22	3		3			
13	4		5	3		4	2	3	2			
14	3		1	3	6	2		3	3			
15	7	14	2	3	5	2		2	9			
16		4			3	1	7	1				
17	8	4		7	4		3	2				
18	7	5		3		1	3		4			
19	5	5		5		9	5		5			
20	7	10		3		5	4	2	6			
21	6			4	41	4		2	0			
22	5	5		2	4	4		3	11			
23		4			3	2	3					
24	29	4		8	3	3	3	3				
25	2	5		3	2	3	3		6			
26	3	4	17	5	3	4	5		4			
27	6	2	15	4		7		2	4			
28	4		2	4	9	3		7	7			
29		9	2	4	2	2		3	9			
30		8	4		4			9	18			
31		3		5	2		23					
計	124	122	80	107	148	128	98	81	134	0	0	0
平均	6	5	5	4	6	5	5	4	6	#DIV/0!	#DIV/0!	#DIV/0!

一般廃棄物処理施設の維持管理記録(炉出口ガス温度)

日 \ 月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1		852	903	896	895	928		882	918			
2		886	894			894	897	901	865			
3	891	878		840	884		897					
4	903	911		898	903	885	908		893			
5	902	908	877	917	896	900	905		896			
6	899	897	855	911		907	900	877	920			
7	918		890	918	860	919	912	898	921			
8	878	876	888	914	866	853		892	903			
9		916	923		906		882	920				
10	902	903		866	923		933	912				
11	915	890		902	909	863	900		873			
12	906	882	875	913	911	825	906		894			
13	900		892	916		900	897	875	905			
14	911	842	912	907	874	917		887	922			
15	884	892	919	909	886	911		902	871			
16		886			874	925	865	866				
17	862	895		900	893		896	892				
18	872	916		893		891	900		905			
19	893	935		912		898	902		895			
20	904			912		897	927	883	856			
21	912	892		902	796	889		894	872			
22	900	882		930	898	895		903	859			
23		896			918	913	880					
24	910	897	902	876	907		896	892				
25	896	904	937	900	905	894	909		839			
26	898	914	932	899	862	912	926		903			
27	894		918	905		920		896	894			
28	907	874	925	898	890	908		900	918			
29		911		896	905	926		913	913			
30		902			930			925	919			
31				871	922		836					
計	20657	23237	14442	23401	22307	21573	18878	17874	19689	0	0	0
平均	898	894	903	900	892	899	899	894	895	#DIV/0!	#DIV/0!	#DIV/0!

一般廃棄物処理施設の維持管理記録(集じん器ガス温度)

日 \ 月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1		156	162	161	178	164		149	149			
2		166	166			171	168	159	144			
3	148	164		158	173		169					
4	153	174	159	161	177	159	166		141			
5	159	171	161	163	177	169	170		152			
6	157	167	168	168		166	165	151	160			
7	156		164	166	171	166	165	150	158			
8	151	139	179	169	175	163		150	152			
9		158			184		155	151				
10	155	154		162	174		168	154				
11	158	150	164	165	179	155	171		146			
12	155		172	165	177	152	167		151			
13	158	155	175	166		165	163	142	153			
14	161		171	170	170	159		138	153			
15	157	149		167	174	170		145	155			
16		158			175	169	158	145				
17	147	157		160	164		161	148				
18	160	165		169		161	168		150			
19	158	158		171		166	152		151			
20	166	173		171		170	169	141	147			
21	166			171	134	164		150	129			
22	161	156		171	159	166		149	145			
23		156			156	166	155					
24	162	160	153	169	163		165	133				
25	163	158	163	172	167	164	165		148			
26	164	161	167	173	157	169	175		154			
27	163	167	167	174		169		144	160			
28	169		169	173	163	163		149	153			
29		155		175	168	168		149	159			
30		159			167			141	158			
31		162		165	162		142					
計	3647	4148	2660	4355	4215	3951	3428	2923	3324	0	0	0
平均	159	160	166	168	169	165	163	146	151	#DIV/0!	#DIV/0!	#DIV/0!